

//सर्वे भवंतु सुखिनः सर्वे संतु निरामया//



प्राथमिक आरोग्य केंद्र रुईछत्रपती  
तालुका पारनेर



दुरध्वनी क्रमांक-  
phcrui@rediffmail.com

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CERTIFICATE

No. Asta/40/2023

Date: - 23/06/2023

It is certified that an inspection team headed by **Dr. Sucheta Rathod** from **Primary Health Center Rui Chhatrapati Tal. Parner Dist. Ahmednagar** inspected the **Stella Maris Convent School, Hanga Tal. Parner Dist. Ahmednagar**, on **23/06/2023** and found that the **Stella Maris Convent School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U. T. Govt.

Again I am attaching this Water testing report, as per this report this water is portable for drinking.

The above is valid for a period of ...1 Year.....



*S. Rathod*  
Medical Officer  
Primary Health Centre Rui Chhatrapati  
Tal. Parner, Dist. Ahmednagar

Signature with Seal .....  
Name.. *Dr. Sucheta Rathod*...  
Designation.. *Medical officer*.....

Name & Address of the Office / Department.. *Rui Chhatrapati Tal. Parner*  
*Dist. Ahmednagar*

To  
*Stella Maris Convent School,*  
*Hanga, Tal. Parner, Dist. Ahmednagar.*

*Chandni*  
MANAGER  
Stella Maris Convent School  
Hanga, Tal. Parner,  
Dist. Ahmednagar, Pin-414301

*S. M.*  
PRINCIPAL  
Stella Maris Convent School  
Hanga, Tal. Parner,  
Dist. Ahmednagar, Pin-414301

Government Of Maharashtra  
Ground Water Survey and Development Agency

Senior Geologist  
Groundwater Survey &  
Development, Agency, Ahmednagar  
Hatampura Chouk, Kothi Road  
Ahmednagar-414001  
E.mail- gsdanagar@rediffmail.com



Landline No . 024 1-2414800  
Landline No 0241-2326017

Outward/SG/GSDA/Anagar/491 /2023

Date -- 22/06/2023


To,  
The Principal  
Stella Maris Convent School,  
Hanga, Tal - Parner  
Dist- Ahmednagar

Subject : Inspection Report of the Drinking Water Purification Machine of School at  
Hanga, Tal- Parner


Ref -- Your Letter No SMCSH/2023 21 dated 19.06.2023

With Reference to the above subject the 3 each sample for Chemical and mineral testing send by you from the water purification machine of Stella Maris Convent School, Hanga had received by at the district laboratory Ahmednagar and the chemical and mineral test report of the said samples forwarded along with this letter



  
Senior Geologist,

Groundwater Surveys & Development, Agency  
Ahmednagar



MANAGER  
Stella Maris Convent School  
Hanga, Tal. Parner,  
Dist. Ahmednagar, Pin-414301



PRINCIPAL  
Stella Maris Convent School  
Hanga, Tal. Parner,  
Dist. Ahmednagar, Pin-414301

महाराष्ट्रशासन  
पाणी पुरवठा व स्वच्छता विभाग



वरिष्ठ भूवैज्ञानिक  
भूजल सर्वेक्षण आणि विकास यंत्रणा  
हातमपुरा चौक, कोठीरोड,  
अहमदनगर-४१४००१

दुरध्वनीक्रं. ०२४१-२३२६०१७  
दुरध्वनीक्रं. ०२४१-२४१४८००  
ईमेल-labgsdanagar@gmail.com  
gsdanagar@rediffmail.com

**Report-On Chemical Examination Of Water For Drinking Purpose**

Date of Collection  
20.06.2023

Date Of Receipt  
20.06.2023

Date of Examination  
22.06.2023

**Details Of Sample**


Village-Hanga ,Tal. Parner, District - Ahmednagar

Name of Applicant- Stella Maris Convent School Hanga ,Supa Parner Road

Type Of Source -

Sr. No.	Test Parameter	unit	BIS Specification		Results	Remark
			10500:2012			
			Normal Values			
			Desirable Limits	Permissible Limits		
1	pH	-	6.5-8.5	--	7.68	Sample is potable /Chemically & Biologically fit for drinking
2	Alkalinity	mg/litre	200	600	41	
3	Total Dissolved Solids	mg/litre	500	2000	192	
4	Turbidity	NTU	1	5	0.18	
5	Hardness	mg/litre	200	600	102	
6	Chlorides	mg/litre	250	1000	27	
7	Fluorides	mg/litre	1.0	1.5	BDL	
8	Nitrates	mg/litre	45	No Relaxation	2.82	
9	Sulphates	mg/litre	200	400	1.55	
10	Iron	mg/litre	0.3	No Relaxation	BDL	
11	EC	mg/litre	--	--	300	
12	Total Coliform	-	--	--	0	
13	E. Coli	-	--	--	0	

- This Report is Strictly Only for the Sample, submitted to this Laboratory
- This Analysis Report is strictly to be used for domestic usage of water only and not for any commercial purpose.

  
MANAGER  
Stella Maris Convent School  
Hanga, Tal. Parner,  
Dist. Ahmednagar, Pin-414301

  
PRINCIPAL  
Stella Maris Convent School  
Hanga, Tal. Parner,  
Dist. Ahmednagar, Pin-414301

महाराष्ट्रशासन  
पाणी पुरवठा व स्वच्छता विभाग



वरिष्ठ भूवैज्ञानिक  
भूजल सर्वेक्षण आणि विकास यंत्रणा  
हातमपुरा चौक, कोठीरोड,  
अहमदनगर-४१४००१

दुरध्वनीक्रं. ०२४१-२३२६०१७  
दुरध्वनीक्रं. ०२४१-२४१४८००  
ईमेल-labgsdanagar@gmail.com  
gsdanagar@rediffmail.com

**Report On Chemical Examination Of Water For Drinking Purpose**

Date of Collection  
20.06.2023

Date Of Receipt  
20.06.2023

Date of Examination  
22.06.2023

**Details Of Sample**

Village-Hanga ,Tal. Parner, District - Ahmednagar

Name of Applicant- Stella Maris Convent School Hanga ,Supa Parner Road

Type Of Source -

Sr. No.	Test Parameter	unit	BIS Specification		Results	Remark
			10500:2012			
			Normal Values			
			Desirable Limits	Permissible Limits		
1	pH	-	6.5-8.5	--	7.74	Sample is potable /Chemically & Biologically fit for drinking
2	Alkalinity	mg/litre	200	600	49	
3	Total Dissolved Solids	mg/litre	500	2000	202	
4	Turbidity	NTU	1	5	0.15	
5	Hardness	mg/litre	200	600	104	
6	Chlorides	mg/litre	250	1000	31	
7	Fluorides	mg/litre	1.0	1.5	BDL	
8	Nitrates	mg/litre	45	No Relaxation	2.95	
9	Sulphates	mg/litre	200	400	1.37	
10	Iron	mg/litre	0.3	No Relaxation	BDL	
11	EC	mg/litre	--	--	315	
12	Total Coliform	-	--	--	0	
13	E. Coli	-	--	--	0	

- This Report is Strictly Only for the Sample, submitted to this Laboratory
- This Analysis Report is strictly to be used for domestic usage of water only and not for any commercial purpose.



*[Signature]*

**MANAGER**  
Stella Maris Convent School  
Hanga, Tal. Parner,  
Dist. Ahmednagar, Pin-414301

*[Signature]*

वरिष्ठ भूवैज्ञानिक  
भूजल सर्वेक्षण आणि विकास यंत्रणा  
अहमदनगर करिता

*[Signature]*

**PRINCIPAL**  
Stella Maris Convent School  
Hanga, Tal. Parner,  
Dist. Ahmednagar, Pin-414301

महाराष्ट्रशासन  
पाणी पुरवठा व स्वच्छता विभाग

वरिष्ठ भूवैज्ञानिक  
भूजल सर्वेक्षण आणि विकास यंत्रणा  
हातमपुरा चौक,कोठीरोड,  
अहमदनगर-४१४००१



दुरध्वनीक्रं. ०२४१-२३२६०१७  
दुरध्वनीक्रं. ०२४१-२४१४८००  
ईमेल-labgsdanagar@gmail.com  
gsdanagar@rediffmail.com

**Report On Chemical Examination Of Water For Drinking Purpose**

Date of Collection

20.06.2023

Date Of Receipt

20.06.2023

Date of Examination

22.06.2023

**Details Of Sample**

Village-Hanga ,Tal. Parner, District - Ahmednagar

Name of Applicant- Stella Maris Convent School Hanga ,Supa Parner Road

Type Of Source -


Sr. No.	Test Parameter	unit	BIS Specification		Results	Remark
			10500:2012			
			Normal Values			
			Desirable Limits	Permissible Limits		
1	pH	-	6.5-8.5	--	7.61	Sample is potable /Chemically & Biologically fit for drinking
2	Alkalinity	mg/litre	200	600	34	
3	Total Dissolved Solids	mg/litre	500	2000	196	
4	Turbidity	NTU	1	5	0.12	
5	Hardness	mg/litre	200	600	100	
6	Chlorides	mg/litre	250	1000	29	
7	Fluorides	mg/litre	1.0	1.5	BDL	
8	Nitrates	mg/litre	45	No Relaxation	2.80	
9	Sulphates	mg/litre	200	400	1.30	
10	Iron	mg/litre	0.3	No Relaxation	BDL	
11	EC	mg/litre	--	--	306	
12	Total Coliform	-	--	--	0	
13	E. Coli	-	--	--	0	

- This Report is Strictly Only for the Sample, submitted to this Laboratory
- This Analysis Report is strictly to be used for domestic usage of water only and not for any commercial purpose.

  
MANAGER

Stella Maris Convent School  
Hanga, Tal. Parner,  
Dist. Ahmednagar, Pin-414301



  
PRINCIPAL

वरिष्ठ भूवैज्ञानिक  
भूजल सर्वेक्षण आणि विकास यंत्रणा  
अहमदनगर कनिष्ठा  
Stella Maris Convent School  
Hanga, Tal. Parner,  
Dist. Ahmednagar, Pin-414301